



# *Peabody Municipal Light Plant*

Warren Street Extension • Peabody, Massachusetts 01960 • Telephone: 978-531-5975 FAX: 978-531-5476

## **ADDENDUM NO. 1**

**(11/14/2017)**

The purpose of this addendum is to provide an update and confirm a clarification that surfaced after the release of the “Ipswich River – 25KV Switchgear” bid documents, released on 11/3/17.

1. Each firm shall submit with their proposal, a bid bond or a certified check equal to five percent (5%) of the lump sum for project bid prices or five percent (5%) of the total annual cost for per unit bid prices. If the bid bond or certified check is not included, proposals shall be rejected. (The bid bond will be returned within fourteen (14) days after the award of contract).
2. In section 2.04 (Circuit Breakers), item A.17., should now read “**Manufacturer: Square D type VR, catalog number VR-2702520, or Eaton type VCP-W, catalog number 8237A12G12 (no exceptions).**”