

PEABODY MUNICIPAL LIGHT PLANT
SPECIFICATIONS FOR
INSULATION PIERCING CONNECTORS

ADDENDUM #1 (BOLD ITALIC SEE BELOW)

The Peabody Municipal Light Plant is seeking firm price bids for INSULATION PIERCING CONNECTORS. The bids shall be for orders placed within a ONE (1) YEAR period from the date the contract is signed. If there is a price escalation formula, please state the formula and the date of escalation on the Bid Form.

It is the intention of the Peabody Municipal Light Plant to purchase up to ***seven thousand five hundred (7,500)*** insulation piercing connectors during the contract period. The actual quantity ordered will be a function of the usage requirements of the Peabody Municipal Light Plant's system during the contract period.

DESCRIPTION: 600V, LOW VOLTAGE INSULATION PIERCING CONNECTORS, WITH THE FOLLOWING CHARACTERISTICS:

- Main AWG: 6 – 4/0
- Tap AWG: 14 – 8
- ***Hex shear head bolt***
- Silicon based lubricant
- Sicame #TTD0610F, ***TE Connectivity 1-708052-1 (KZEP 4/0)***, or approved equivalent