

## **ADDENDUM NO. 1**

**(6/8/2018)**

This addendum #1 to the “Relay and Control Cabinets – Waters River Substation” bid documents, released on 5/22/18, contains responses to several questions that have come up during the bid process:

Q. Does PMLP want individual cabinets or does PMLP want the cabinets “skidded” at the factory so they are fully assembled in a row affixed to a steel base and fully interconnected instead of individual cabinets?

A. PMLP wants individual cabinets which will be assembled on site by others.

Q. For the panel to panel interconnect wiring are we to assume SIS wire or fully jacketed tray cable?

A. SIS cable shall be used for interconnect wiring.

Q. Is there a floor plan available of the room where the cabinets will be installed?

A. Floor plan of the Waters River control house is included in this addendum.

Q. There is a note in the RFP that PMLP does not have heavy equipment to offload/rig the cabinets. Will these cabinets be installed on the first floor of a building or will it be higher than the first floor requiring the vendor to utilize a lull or boom truck?

A. The vendor will be responsible for delivery only, all offloading and installation will be taken care of by others.